



California Regional Water Quality Control Board San Diego Region



Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Linda S. Adams
Secretary for
Environmental Protection

Edmund G. Brown, Jr.
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

March 23, 2011

In reply refer to:
254912:rsunjed

Mr. Brian Gordon
NAVFAC Southwest
Environmental Program N 451.12
937 North Harbor Drive
San Diego, CA 92132-0058

Dear Mr. Gordon:

**SUBJECT: REVIEW OF MONITORING REPORT FOR ORDER NO. 93-11
U.S. NAVY S.E.R.E. CAMP, WARNER SPRINGS**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the July-December 2010 semiannual and the January-December 2010 annual monitoring reports submitted by Department of the Navy in accordance with Monitoring and Reporting Program No. 93-11.

The San Diego Water Board identified the following violations of Section B.1 (Discharge Specifications) of Order No. 93-11 in the reports submitted:

1. The 12-month average discharge specification for Total Dissolved Solids (TDS), established at 900 milligrams per liter (mg/L), was exceeded on September 20, 2010 with a reported value of 1,245 mg/L.
2. The daily maximum discharge specification for TDS, established at 300 mg/L over the water supply TDS concentration, was exceeded on September 20, 2010 with a reported value of 1,340 mg/L. The reported effluent TDS concentration was 494 mg/L over the water supply TDS concentration of 846 mg/L.


Please take steps to implement follow-up actions necessary to ensure that the violations noted do not occur in the future. These violations subject the US Navy to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the US Navy to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

California Environmental Protection Agency

The next monitoring report required to be submitted is the January-June 2011 semiannual report, which is due by July 30, 2011.

In the subject line of any response, please include the requested **"In reply refer to:"** information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ray Sunjed at (858) 627-3977 or rsunjed@waterboards.ca.gov.

Sincerely,



Brian D. Kelley, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 377872
Violation ID: 893030 and 893031

